



ROC L-16 092461

FIRE EQUIPMENT SALES
AND SERVICE CORPORATION

ROC L-67 092462

3107 W. VIRGINIA AVE. ★ PHX, AZ 85009-1604 ★ (602)433-2484 ★ Fax (602)433-9626
2921 S. KISH AVE ★ YUMA, AZ 85365 ★ (928) 341-0025 ★ Fax (928) 341-0386
SHOW LOW ★ PINETOP ★ LAKESIDE ★ (928) 532-2292

11/1/2012

Jeff Akins
Blue Ridge High School Main
1200 W. Mountain Bl.
Lake Side, Az. 85929

Phone: 928-369-3945
E-Mail: jakins@brusdk12.az.us
DNR#: SLM176

RE: Fire alarm repairs per system report dated 7/30/2012. Staff Lounge

American Fire Equipment Sales & Service would like to present you with the following proposal for the above referenced facility.

Deficiencies Noted

- ▶ Horn / Strobes did not completely function in following areas: New gym toilet rm. 626, new gym coaches office, new gym girls locker rm., new gym hall outside of 633 mens restroom.
- ▶ Building has a mix of older mechanical horn strobes and newer Simplex horn strobes, none are synchronized.
- ▶ All sprinkler tampers report as troubles on zone 1, not supervisories.
- ▶ Kitchen has Simplex conventional panel that is powered down. Panel has short on initiating circuit. Panel does not report to main panel. Batteries in panel are bad as well.

Scope of Work

- ▶ Replacement of horn / strobes in toilet rm. 626, coaches office, girls locker rm. Shower area, gym hall outside mens restroom 633.
- ▶ Synchronization of old mechanical horn strobes with Simplex horn strobes.
- ▶ Troubleshooting and reprogramming of sprinkler tampers to report as supervisories not troubles.
- ▶ Troubleshooting and repairing of existing of Simplex convential panel. Replacement of panel batteries.

Cost Summary

American Fire Equipment is pleased to provide and complete the above scope of work for the sum of:

Total Labor	\$1,530.00
Total Materials	\$556.64
Sub Total	\$2,086.64
Tax	\$51.77
Total Proposal	<u>\$2,138.41</u>